

BP-14 Initial Rate Proposal

Power Loads and Resources Study

November 2012

BP-14-E-BPA-03



BP-14 Initial Rate Proposal

Power Loads and Resources Study

November 2012

BP-14-E-BPA-03



This page intentionally left blank.

POWER LOADS AND RESOURCES STUDY

TABLE OF CONTENTS

	Page
Commonly Used Acronyms	iii
1. INTRODUCTION AND OVERVIEW	1
1.1 Introduction.....	1
1.2 Overview of Methodology.....	2
2. FEDERAL SYSTEM LOAD OBLIGATION FORECAST.....	5
2.1 Overview.....	5
2.2 Public Agencies' Total Retail Load and Firm Requirement PSC Obligation Forecasts	5
2.2.1 Load-Following PSC Obligation Forecasts	6
2.2.2 Slice/Block PSC Obligation Forecasts.....	7
2.2.3 Sum of Load-Following and Slice/Block PSC Obligation Forecasts	9
2.3 Investor-Owned Utilities Sales Forecast.....	9
2.4 Direct Service Industry Sales Forecast	10
2.5 USBR Irrigation District Obligations	11
2.6 Other BPA Contract Obligations	11
3. RESOURCE FORECAST	13
3.1 Federal System Resource Forecast	13
3.1.1 Overview.....	13
3.1.2 Federal System Hydro Generation.....	13
3.1.2.1 Regulated Hydro Generation Forecast.....	14
3.1.2.2 Independent Hydro Generation Forecast	24
3.1.3 Other Federal System Generation.....	25
3.1.4 Federal System Contract Purchases.....	26
3.2 Regional Hydro Resources	28
3.2.1 Overview.....	28
3.2.2 PNW Regional 80 Water Year Hydro Generation.....	28
3.3 4(h)(10)(C) Credits	29
3.3.1 Overview.....	29
3.3.2 Forecast of Power Purchases Eligible for 4(h)(10)(C) Credits.....	30
3.4 Use of Tier 1 System Firm Critical Output Calculation	32
4. FEDERAL SYSTEM LOAD-RESOURCE BALANCE.....	35
4.1 Overview.....	35
4.2 Federal System Energy Load-Resource Balance.....	35

SUMMARY TABLES

Table 1 Regional Dialogue Preference Load Obligations	36
Table 2 Loads and Resources – Federal System Summary	36
Table 3 Loads and Resources – Federal System Components.....	37

COMMONLY USED ACRONYMS

AAC	Anticipated Accumulation of Cash
AGC	Automatic Generation Control
ALF	Agency Load Forecast (computer model)
aMW	average megawatt(s)
AMNR	Accumulated Modified Net Revenues
ANR	Accumulated Net Revenues
ASC	Average System Cost
BiOp	Biological Opinion
BPA	Bonneville Power Administration
Btu	British thermal unit
CDD	cooling degree day(s)
CDQ	Contract Demand Quantity
CGS	Columbia Generating Station
CHWM	Contract High Water Mark
COE, Corps, or USACE	U.S. Army Corps of Engineers
Commission	Federal Energy Regulatory Commission
Corps, COE, or USACE	U.S. Army Corps of Engineers
COSA	Cost of Service Analysis
COU	consumer-owned utility
Council or NPCC	Northwest Power and Conservation Council
CP	Coincidental Peak
CRAC	Cost Recovery Adjustment Clause
CSP	Customer System Peak
CT	combustion turbine
CY	calendar year (January through December)
DDC	Dividend Distribution Clause
<i>dec</i>	decrease, decrement, or decremental
DERBS	Dispatchable Energy Resource Balancing Service
DFS	Diurnal Flattening Service
DOE	Department of Energy
DSI	direct-service industrial customer or direct-service industry
DSO	Dispatcher Standing Order
EIA	Energy Information Administration
EIS	Environmental Impact Statement
EN	Energy Northwest, Inc.
EPP	Environmentally Preferred Power
ESA	Endangered Species Act
e-Tag	electronic interchange transaction information
FBS	Federal base system
FCRPS	Federal Columbia River Power System
FCRTS	Federal Columbia River Transmission System
FELCC	firm energy load carrying capability
FHFO	Funds Held for Others
FORS	Forced Outage Reserve Service

FPS	Firm Power Products and Services (rate)
FY	fiscal year (October through September)
GARD	Generation and Reserves Dispatch (computer model)
GEP	Green Energy Premium
GRSPs	General Rate Schedule Provisions
GTA	General Transfer Agreement
GWh	gigawatthour
HDD	heating degree day(s)
HLH	Heavy Load Hour(s)
HOSS	Hourly Operating and Scheduling Simulator (computer model)
HYDSIM	Hydrosystem Simulator (computer model)
ICE	IntercontinentalExchange
<i>inc</i>	increase, increment, or incremental
IOU	investor-owned utility
IP	Industrial Firm Power (rate)
IPR	Integrated Program Review
IRD	Irrigation Rate Discount
IRM	Irrigation Rate Mitigation
IRMP	Irrigation Rate Mitigation Product
JOE	Joint Operating Entity
kW	kilowatt (1000 watts)
kWh	kilowatthour
LDD	Low Density Discount
LLH	Light Load Hour(s)
LRA	Load Reduction Agreement
Maf	million acre-feet
Mid-C	Mid-Columbia
MMBtu	million British thermal units
MNR	Modified Net Revenues
MRNR	Minimum Required Net Revenue
MW	megawatt (1 million watts)
MWh	megawatthour
NCP	Non-Coincidental Peak
NEPA	National Environmental Policy Act
NERC	North American Electric Reliability Corporation
NFB	National Marine Fisheries Service (NMFS) Federal Columbia River Power System (FCRPS) Biological Opinion (BiOp)
NLSL	New Large Single Load
NMFS	National Marine Fisheries Service
NOAA Fisheries	National Oceanographic and Atmospheric Administration Fisheries
NORM	Non-Operating Risk Model (computer model)
Northwest Power Act	Pacific Northwest Electric Power Planning and Conservation Act
NPCC or Council	Pacific Northwest Electric Power and Conservation Planning Council

NPV	net present value
NR	New Resource Firm Power (rate)
NT	Network Transmission
NTSA	Non-Treaty Storage Agreement
NUG	non-utility generation
NWPP	Northwest Power Pool
OATT	Open Access Transmission Tariff
O&M	operation and maintenance
OATI	Open Access Technology International, Inc.
OMB	Office of Management and Budget
OY	operating year (August through July)
PF	Priority Firm Power (rate)
PFp	Priority Firm Public (rate)
PFx	Priority Firm Exchange (rate)
PNCA	Pacific Northwest Coordination Agreement
PNRR	Planned Net Revenues for Risk
PNW	Pacific Northwest
POD	Point of Delivery
POI	Point of Integration or Point of Interconnection
POM	Point of Metering
POR	Point of Receipt
Project Act	Bonneville Project Act
PRS	Power Rates Study
PS	BPA Power Services
PSW	Pacific Southwest
PTP	Point to Point Transmission (rate)
PUD	public or people's utility district
RAM	Rate Analysis Model (computer model)
RAS	Remedial Action Scheme
RD	Regional Dialogue
REC	Renewable Energy Certificate
Reclamation or USBR	U.S. Bureau of Reclamation
REP	Residential Exchange Program
RevSim	Revenue Simulation Model (component of RiskMod)
RFA	Revenue Forecast Application (database)
RHWM	Rate Period High Water Mark
RiskMod	Risk Analysis Model (computer model)
RiskSim	Risk Simulation Model (component of RiskMod)
ROD	Record of Decision
RPSA	Residential Purchase and Sale Agreement
RR	Resource Replacement (rate)
RRS	Resource Remarketing Service
RSS	Resource Support Services
RT1SC	RHWM Tier 1 System Capability
RTO	Regional Transmission Operator
SCADA	Supervisory Control and Data Acquisition

SCS	Secondary Crediting Service
Slice	Slice of the System (product)
T1SFCO	Tier 1 System Firm Critical Output
TCMS	Transmission Curtailment Management Service
TOCA	Tier 1 Cost Allocator
TPP	Treasury Payment Probability
Transmission System Act	Federal Columbia River Transmission System Act
TRL	Total Retail Load
TRM	Tiered Rate Methodology
TS	BPA Transmission Services
TSS	Transmission Scheduling Service
UAI	Unauthorized Increase
ULS	Unanticipated Load Service
USACE, Corps, or COE	U.S. Army Corps of Engineers
USBR or Reclamation	U.S. Bureau of Reclamation
USFWS	U.S. Fish and Wildlife Service
VERBS	Variable Energy Resources Balancing Service (rate)
VOR	Value of Reserves
VR1-2014	First Vintage rate of the BP-14 rate period
WECC	Western Electricity Coordinating Council (formerly WSCC)
WIT	Wind Integration Team
WSPP	Western Systems Power Pool

1. INTRODUCTION AND OVERVIEW

1.1 Introduction

The Power Loads and Resources Study (Study) contains the load and resource data used to develop Bonneville Power Administration's (BPA's) wholesale power rates. This Study illustrates how each component of the loads and resources analysis is completed, how the components relate to each other, and how they fit into the rate development process. The Power Loads and Resources Study Documentation (Documentation), BP-14-E-BPA-03A, contains details and results supporting this Study.

This Study has two primary purposes: (1) to determine BPA's load and resource balance (load-resource balance); and (2) to calculate various inputs that are used in other studies and calculations within the rate case. The purpose of BPA's load-resource balance analysis is to determine whether BPA's resources meet, are less than, or are greater than BPA's load for the rate period, fiscal years (FY) 2014–2015. If BPA's resources are less than the amount of load forecast for the rate period, some amount of system augmentation is required to achieve load-resource balance.

This Study provides inputs into various other studies and calculations in the ratemaking process. The results of this Study provide data to (1) the Power Revenue Requirement Study, BP-14-E-BPA-02; (2) the Power Rates Study (PRS), BP-14-E-BPA-01; (3) the Power Risk and Market Price Study, BP-14-E-BPA-04; and (4) the Generation Inputs Study, BP-14-E-BPA-05.

1.2 Overview of Methodology

This Study includes three main components: (1) load data, including a forecast of the Federal system load and contract obligations; (2) resource data, including Federal system resource and contract purchase estimates, total Pacific Northwest (PNW) regional hydro resource estimates, and the estimated amount of power purchases that are eligible for section 4(h)(10)(C) credits; and (3) the Federal system load-resource balance, which compares Federal system sales, loads, and contract obligations to the Federal system generating resources and contract purchases.

The first component of the Study, the Federal system load obligation forecast, estimates the firm energy that BPA expects to serve during FY 2014–2015 under firm requirements contract obligations and other BPA contract obligations. The load estimates are discussed in section 2 of this Study and are detailed in the Documentation.

The second component of the Study is the resource component, which includes the forecast of (1) Federal system resources; (2) PNW regional hydro resources; and (3) power purchases eligible for 4(h)(10)(C) credits. The Federal system resource forecast includes hydro and non-hydro generation estimates plus power deliveries from BPA contract purchases. The Federal system resource estimates are discussed in section 3.1 of this Study and are detailed in the Documentation. The PNW regional hydro resources include all hydro resources in the Pacific Northwest, whether Federally or non-Federally owned. Energy generation estimates of the PNW regional hydro resources are used in the forecast of electricity market prices in the Power Risk and Market Price Study, BP-14-E-BPA-04. The regional hydro estimates are discussed in section 3.2 of this Study and are detailed in the Documentation. The resource estimates used to calculate the 4(h)(10)(C) credits are discussed in section 3.3 of this Study, and the estimated power purchases eligible for 4(h)(10)(C) credits are detailed in the Documentation.

1 These 4(h)(10)(C) credits are taken by BPA to offset the non-power share of fish and wildlife
2 costs incurred as mitigation for the impact of the Federal hydro system. See section 3.3.1.
3 The third component of this Study is the Federal system load-resource balance, which completes
4 BPA's load and resource picture by comparing total Federal system load obligations to Federal
5 system resource output for FY 2014–2015. Federal system resources under critical water
6 conditions minus loads yields BPA's estimated Federal system monthly and annual firm energy
7 surplus or deficit. If there is a forecast annual average firm energy deficit, system augmentation
8 is added to Federal system resources to balance loads and resources. The load-resource balance
9 is discussed in section 4 of this Study and is detailed in the Documentation.

10
11 Throughout the Study and Documentation, the loads and resource forecasts are shown using
12 three different measurements. The first, energy in average megawatts (aMW), is the average
13 amount of energy produced or consumed over a given time period, in most cases a month. The
14 second measurement, heavy load hours in megawatthours (MWh), is the total MWh generated or
15 consumed over heavy load hours. Heavy load hours (referred to as either Heavy or HLH) can
16 vary by contract but generally are hours 6 a.m. to 10 p.m. (or Hour Ending (HE) 0007 to
17 HE 2200), Monday through Saturday, excluding North American Electric Reliability
18 Corporation (NERC) holidays. The third measurement, light load hours in MWh, is the total
19 MWh generated or consumed over light load hours. Light load hours (referred to as either Light
20 or LLH) can vary by contract but generally are hours 10 p.m. to 6 a.m. (or HE 2300 to HE 0006),
21 Monday through Saturday, all day Sunday, and holidays defined by NERC. These
22 measurements are used to ensure that BPA will have adequate resources to meet the variability
23 of loads.

This page intentionally left blank.

2. FEDERAL SYSTEM LOAD OBLIGATION FORECAST

2.1 Overview

The Federal System Load Obligation forecast includes: (1) BPA's projected firm requirements power sales contract (PSC) obligations to consumer-owned utilities (COUs) and Federal agencies (together, for purposes of this Study, called Public Agencies or Public Agency Customers); (2) PSC obligations to investor-owned utilities (IOUs); (3) PSC obligations to direct-service industries (DSIs); (4) contract obligations to the U.S. Bureau of Reclamation (USBR); and (5) other BPA contract obligations, including contract obligations outside the Pacific Northwest region (Exports) and contract obligations within the Pacific Northwest region (Intra-Regional Transfers (Out)). Summaries of BPA's forecast of these obligations follow in this section.

2.2 Public Agencies' Total Retail Load and Firm Requirement PSC Obligation Forecasts

In December 2008, BPA executed power sales contracts with Public Agencies under which BPA is obligated to provide power deliveries from October 1, 2011, through September 30, 2028. These contracts are referred to as Contract High Water Mark (CHWM) contracts. Three types of CHWM contracts were offered to customers: Load-Following, Slice/Block, and Block (with or without Shaping Capacity). One hundred eighteen Public Agency customers signed the Load-Following contracts, 17 signed the Slice/Block contract, and none signed the Block contract.

Under these CHWM contracts, customers must make elections to serve some of their load by (1) adding new non-Federal resources; (2) buying power from sources other than BPA; and/or

(3) requesting BPA to supply power. The quantities of these elections factor into the forecasting process, reducing the energy BPA will be obligated to serve.

2.2.1 Load-Following PSC Obligation Forecasts

The Load-Following product provides firm power to meet the customer's total retail load, less the firm power from the customer's non-Federal resource generation amounts and purchases from other suppliers used to serve its total retail load.

The total monthly firm energy requirements PSC obligation forecast for Public Agency customers that purchase the Load-Following product is based on the sum of the utility-specific firm requirements PSC obligation forecasts, which are customarily produced by BPA analysts. The method used for preparing the firm requirements PSC obligation forecasts is as follows.

First, utility-specific forecasts of total retail load are produced using least-squares regression-based models on historical monthly energy loads. These models may include several independent variables, such as a time trend, heating degree days, cooling degree days, and monthly indicator variables. Heating and cooling degree days are measures of temperature effects to account for changes in electricity usage related to temperature changes. Heating degree days are calculated when the temperature is below a base temperature, such as 65 degrees; similarly, cooling degree days are calculated when the temperature is above a base temperature. The results from these computations are utility-specific monthly forecasts of total retail energy load. The total retail energy load is then split into HLH and LLH time periods using recent historical relationships.

The monthly peak loads are forecast in a similar fashion as the energy loads, including the use of historical data for the customers' peaks.

1
2 Second, estimates of customer-owned and consumer-owned dedicated resource generation and
3 contract purchases dedicated to serve retail loads are subtracted from the utility-specific total
4 retail load forecasts to produce a firm requirement PSC obligation forecast for each utility.

5 These firm requirement PSC obligation forecasts provide the basis for the Load Following
6 product sales projections incorporated in BPA ratemaking.

7
8 A list of the 118 Public Agency customers that have purchased the Load-Following product is
9 shown in Documentation Table 1.1.1. BPA's forecast of the total Public Agency PSC obligation
10 is summarized in Documentation Table 1.2.1 for energy, Table 1.2.2 for HLH, and Table 1.2.3
11 for LLH, on line 3 (Load Following). Line 3 includes Federal Agencies, which are summarized
12 on line 8 (Federal Entities). This forecast is also included in the calculation of the load-resource
13 balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on line 2
14 (Federal Agencies) and line 6 (Load-Following 2012 PSC).

15 16 **2.2.2 Slice/Block PSC Obligation Forecasts**

17 The Slice/Block product provides firm requirements power to serve the customer's total retail
18 load up to its planned net requirement. For each fiscal year, the planned annual Slice amount is
19 adjusted based on BPA's calculation of the customer's planned net requirement under the
20 contract. The Block portion of the Slice/Block product provides a planned amount of firm
21 requirements power in a fixed monthly shape, while the Slice portion provides planned amounts
22 of firm requirements power in the shape of BPA's generation from the Tier 1 System. The PSC
23 obligation of the total Slice product monthly energy firm requirements is forecast by multiplying
24 the forecast monthly Tier 1 System output by the sum of the individual customers' Slice

Percentages as stated in Slice/Block contracts. See Section 3.4 of this Study and Power Rates Study, BP-14-E-BPA-01, section 1.6..

The PSC obligation of the Block product monthly energy firm requirements for each Slice/Block customer is forecast as follows:

1. Forecast the planned annual net requirements load.
2. Compute the planned annual amount of firm requirements power available through the Slice Product by multiplying the forecast annual Tier 1 System output by the Slice Percentage stated in the customer's Slice/Block contract.
3. Compute the annual Block product firm requirements obligation by subtracting the Slice annual amount of firm requirements power (Step 2) from the planned annual net requirement (Step 1).
4. Compute each month's Block product firm requirements obligation for each customer by multiplying the annual Block product firm requirements obligation (Step 3) by each month's Block shaping factor stated in the customer's Slice/Block contract.

The total monthly Block product firm requirements obligation is computed as the sum of the monthly Block product firm requirements obligations, computed in step 4 above, for each Slice/Block customer.

A list of the 17 Slice/Block customers is shown in Documentation Table 1.1.2. BPA's forecast of the total Slice/Block PSC Obligation is summarized in Documentation Table 1.2.1 for energy, Table 1.2.2 for HLH, and Table 1.2.3 for LLH, on lines 8 (Slice Right to Power) and 11 (Tier 1 Block). This forecast is also included in the calculation of the load-resource balance, Table 4.1.1

for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on lines 7 (Slice Block 2012 PSC) and 8 (Slice Right to Power 2012 PSC).

2.2.3 Sum of Load-Following and Slice/Block PSC Obligation Forecasts

The sum of the projected firm requirements PSC obligations for customers with CHWM contracts comprises the Public Agencies Preference Customers' portion of the Priority Firm Public (PFp) load obligation forecast. Each customer's load obligation forecast accounts for the reported amount of conservation that the customer plans to achieve during the FY 2014–2015 rate period. The amount of anticipated BPA-funded conservation beyond what the customers have reported is also accounted for in the total load obligation forecast. Thus, the sum of the projected firm requirements PSC obligations for customers with CHWM contracts is reduced based on the total anticipated BPA-funded conservation savings during the rate period. The BPA-funded conservation reductions are estimated to be 29.7 aMW for FY 2014 and 29.7 aMW for 2015. Table 1 presents the PF load obligation by product and total PF load obligation adjusted for conservation savings.

2.3 Investor-Owned Utilities Sales Forecast

The six IOUs in the PNW region are Avista Corporation, Idaho Power Company, NorthWestern Energy Division of NorthWestern Corporation (formerly Montana Power Company), PacifiCorp, Portland General Electric Company, and Puget Sound Energy, Inc. Most of the IOUs have signed BPA power sales contracts for FY 2011 through 2028; however, no IOUs have chosen to take service under these contracts. If requested, BPA would serve any net requirements of an IOU at the New Resource Firm Power (NR-14) rate. No net requirements power sales to regional IOUs are forecast for FY 2014–2015 based on BPA's current contracts with the regional

1 IOUs. The IOUs will receive benefits under the settlement of the Residential Exchange
2 Program (REP), but these benefits are not in the form of actual power deliveries.

4 **2.4 Direct Service Industry Sales Forecast**

5 Currently BPA is making power sales deliveries to Alcoa, Inc. (Alcoa) and Port Townsend Paper
6 Corporation (Port Townsend). Port Townsend's current contract with BPA runs through
7 August 31, 2013, with a proposed amendment starting the following day. Under the proposed
8 amendment, BPA would continue to provide 20.5 aMW through September 30, 2022. However,
9 BPA expects the newly formed Jefferson County PUD to take over Port Townsend's wheel
10 turning load (load not integral to the industrial process) and Port Townsend's Old Corrugated
11 Containers (OCC) recycling plant load, totaling 8.5 aMW, in July 2013. Jefferson County
12 PUD's load forecast reflects these expectations. BPA also assumes in this Study that it will
13 continue to serve the remainder of Port Townsend's load, approximately 12 aMW. The Alcoa
14 contract is for 300 aMW, and the "initial period" of the contract extends through
15 December 2012. BPA has proposed a new contract with Alcoa for 300 aMW that would
16 continue through September 2022; it is currently undergoing public comment. This Study
17 assumes power sales to the DSIs totaling 312 aMW for each year of the rate period, composed of
18 300 aMW for Alcoa and 12 aMW for Port Townsend, all sold at the IP-14 rate.

19
20 The DSI forecast is summarized in Documentation Table 1.2.1 for energy, Table 1.2.2 for HLH,
21 and Table 1.2.3 for LLH, on line 1 (Total Direct Service Industry). This forecast is also included
22 in the calculation of the load-resource balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and
23 Table 4.1.3 for LLH, on line 4 (DSI Obligation).

2.5 USBR Irrigation District Obligations

BPA is obligated to provide power from the Federal system to several irrigation districts associated with USBR projects in the Pacific Northwest. These irrigation districts have been Congressionally authorized to receive power from specified Federal Columbia River Power System (FCRPS) projects as part of the USBR project authorization. BPA does not contract directly with these irrigation districts; instead, there are several agreements between BPA and USBR that provide details on the power deliveries.

A list of USBR irrigation district obligation customers is shown in Documentation Table 1.1.3. BPA's forecast of the total USBR customer load is summarized in Table 1.2.1 for energy, Table 1.2.2 for HLH, and Table 1.2.3 for LLH, on line 14 (U.S. Bureau of Reclamation Obligation). This forecast is also included in the calculation of the load-resource balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on line 3 (USBR Obligation).

2.6 Other BPA Contract Obligations

BPA provides Federal power to customers under a variety of contract arrangements not included in the Public Agencies, IOU, DSI, or USBR forecasts. These contracts include obligations outside the Pacific Northwest region (Exports) and obligations within the Pacific Northwest region. Intra-Regional Transfers (Out) are categorized as: (1) power sales; (2) power or energy exchanges; (3) capacity sales or capacity-for-energy exchanges; (4) power payments for services; and (5) power commitments under the Columbia River Treaty. These arrangements, collectively called "Other Contract Obligations," are specified by individual contract provisions and can have different delivery arrangements and rate structures. BPA's Other Contract Obligations are assumed to be served by Federal system firm resources regardless of weather, water, or

1 economic conditions. These Other Contract Obligations are modeled individually and are
2 specified or estimated for monthly energy in aMW, HLH MWh, and LLH MWh.

3
4 The Pacific Northwest region Contract Obligations (Exports) are detailed in Documentation
5 Table 1.3.1 for energy, Table 1.3.2 for HLH, and Table 1.3.3 for LLH. The Pacific Northwest
6 Intra-Regional Transfers (Out) Contract Obligations are detailed in Documentation Table 2.9.1
7 for energy, Table 2.9.2 for HLH, and Table 2.9.3 for LLH, on line 12 (Total Contracts Out).
8 This forecast is also included in the calculation of the load-resource balance, Table 4.1.1 for
9 energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on lines 9 (Exports) and 10 (Intra-
10 Regional Transfers (Out)).

11
12 Estimates of trading floor sales during the rate period are not included in BPA's load-resource
13 balance used in ratemaking. Revenue impacts of these contract obligations are reflected as
14 presales of secondary energy and are included as secondary revenues credited to non-Slice
15 customers' rates. These contracts are accounted for in the Power Risk and Market Price Study
16 Documentation, BP-14-E-BPA-04A, Tables 18 and 19, as committed sales.

3. RESOURCE FORECAST

3.1 Federal System Resource Forecast

3.1.1 Overview

In the Pacific Northwest, BPA is the Federal power marketing agency charged with marketing power and transmission to serve the firm electric load needs of its customers. BPA does not own generating resources; rather, BPA markets power from Federal and non-Federal generating resources to meet Federal load obligations. In addition, BPA purchases power through contracts that add to the Federal system generating capability. These resources and contract purchases are collectively called “Federal system resources” in this Study. Federal system resources are classified as Federal regulated and independent hydro projects, non-Federal independent hydro projects, other non-Federal resources (renewable, cogeneration, large thermal, wind, and small non-utility generation (NUG) projects), and Federal contract purchases.

3.1.2 Federal System Hydro Generation

Federal system hydro resources are comprised of the generation from regulated and independent hydro projects. Regulated projects and the process used for estimating the generation of regulated hydro projects are detailed in section 3.1.2.1. Independent hydro projects and the methodology for forecasting generation of independent hydro projects are described in section 3.1.2.2. BPA also purchases the output from two small NUG hydro projects. Generation estimates for these small hydro projects were provided by the project’s owner and are assumed not to vary by water year. Small hydro projects are described in section 3.1.3.

3.1.2.1 Regulated Hydro Generation Forecast

BPA markets the generation from the Federal system hydro projects, listed in Documentation Table 2.1.1, lines 1-14. These projects are owned and operated by either the U.S. Army Corps of Engineers (USACE) or USBR.

This Study uses BPA's hydrosystem simulator model, HYDSIM, to estimate the Federal system energy production that can be expected from specific hydroelectric power projects in the PNW Columbia River Basin when operating in a coordinated fashion and meeting power and non-power requirements for 80 water years (October 1928 through September 2008). The hydro projects modeled in HYDSIM are called regulated hydro projects. The hydro regulation study uses individual project operating characteristics and conditions to determine energy production expected from each specific project. Physical characteristics of each project come from annual Pacific Northwest Coordination Agreement (PNCA) data submittals from regional utilities and government agencies involved in the coordination and operation of regional hydro projects. The HYDSIM model provides project-by-project monthly energy generation estimates for the Federal system regulated hydro projects that vary by water year. HYDSIM incorporates and produces data for 14 periods per year, which is monthly data except there are two periods for April and two periods for August. This 14-period data is still referred to as monthly data for simplicity.

There are three main steps of the hydro regulation studies that estimate regulated hydro generation production. First, the Canadian operation is set based on the best available information from the Columbia River Treaty (Treaty) planning and coordination process. The Treaty calls for an Assured Operating Plan (AOP) to be completed six years prior to each operating year and a Detailed Operating Plan (DOP) to be completed if necessary the year prior to the operating year. The DOP reflects modifications to the AOP if agreed to by the U.S. and Canada and is usually completed a few months prior to the operating year. These official DOP studies from the Columbia River Treaty process are not available in time for the rate case initial

1 proposal or final proposal studies. As a surrogate for the official 2014 and 2015 DOP studies,
2 the official 2014 and 2015 AOP studies are used with a few modifications to reflect updates
3 expected in the official DOP studies. These are referred to as “surrogate DOP” studies and
4 reflect the best estimate available for Canadian operations before the official DOP studies are
5 available. The surrogate DOP studies include the official AOP study assumptions plus the
6 following updates: (1) 80-year historical water conditions instead of 70; (2) most recent flood
7 control data provided by the USACE; and (3) most recent plant data available from project
8 owners through the PNCA planning and coordination process.

9
10 Second, an Actual Energy Regulation study (AER step) is run in HYDSIM to determine the
11 operation of the hydro system under each of the 80 years of historical water conditions while
12 meeting the Firm Energy Load Carrying Capability (FELCC) produced in the PNCA final hydro
13 regulation. In this step, the Canadian operation is fixed to the surrogate DOP studies. Also in
14 this step, the U.S. Federal, U.S. non-Federal, and Canadian reservoirs draft water to meet the
15 Coordinated System FELCC while continuing to meet individual reservoir non-power operating
16 requirements.

17
18 Third, an 80-year operational study (OPER step) is run in HYDSIM with the estimated regional
19 firm loads developed for each year of the Study and with any deviations from the PNCA data
20 submittals necessary to reflect expected operations during the rate period. In the OPER step the
21 non-Federal projects are fixed to their operations from the AER step, and the Federal projects
22 operate differently based on the deviations from PNCA data and the estimated regional firm
23 load.

24
25 In summary, a surrogate DOP is used to determine the Canadian operations, an AER step is run
26 based on PNCA data to determine the operation of the non-Federal projects, and an OPER step is

run to determine the operation of the Federal projects based on PNCA data plus additional assumptions needed to reflect expected operations. The end result of these three steps is generally referred to as the hydro regulation study.

Separate hydro regulation studies are incorporated for each year of the rate period for this Study. By modeling hydro regulation studies for individual years, the hydro generation estimates capture changes in variables that characterize yearly variations in the hydro operations due to firm loads, firm resources, markets for hydro energy products in better than critical water conditions, and project operating limitations and requirements. These variables affect the amount and timing of energy available from the hydro system and are changed as necessary to reflect current expectations. Sections 3.1.2.1.1 through 3.1.2.1.4 contain additional details on the process of producing the regulated hydro generation estimates used in this Study.

BPA's forecast for the Federal system regulated hydro generation is detailed in Documentation Table 2.1.1 for energy. An aggregate of the Federal system regulated hydro generation is summarized for HLH in Table 2.1.2 and LLH in Table 2.1.3 on line 17 (Total Regulated Hydro). The HLH and LLH split is based on the aggregated Federal system regulated hydro generation estimates produced by BPA's Hourly Operating and Scheduling Simulator (HOSS) analyses that utilize the HYDSIM hydro regulation studies as their base input. The HOSS model is described in the Generation Inputs Study, BP-14-E-BPA-05, section 3.2.4. This forecast is also included in the calculation of the load-resource balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on line 14 (Regulated Hydro - Net).

The energy for the net regulated hydro generation is provided to the Power Risk and Market Price Study, BP-14-E-BPA-04. The HLH and LLH Federal system regulated hydro generation

estimates are later combined with the Federal system independent hydro HLH-LLH split in the Power Risk and Market Price Study.

3.1.2.1.1 Assumptions in the HYDSIM Hydro Regulation Study

The HYDSIM studies incorporate the power and non-power operating requirements expected to be in effect during the rate period, including those described in the National Oceanographic and Atmospheric Administration (NOAA) Fisheries FCRPS Biological Opinion (BiOp) regarding salmon and steelhead, published May 5, 2008; the NOAA Fisheries FCRPS BiOp Amendment, published May 20, 2010; the U.S. Fish and Wildlife Service (USFWS) FCRPS BiOp regarding bull trout and sturgeon, published December 20, 2000; the USFWS Libby BiOp regarding bull trout and sturgeon, published February 18, 2006; relevant operations described in the Northwest Power and Conservation Council's (NPCC) Fish and Wildlife Program; and other fish mitigation measures. Each hydro regulation study specifies particular hydroelectric project operations for fish, such as seasonal flow objectives, minimum flow levels for fish, spill for juvenile fish passage, reservoir target elevations and drawdown limitations, and turbine operation efficiency requirements.

Additionally, HYDSIM uses hydro plant operating characteristics in combination with power and non-power requirements to simulate the coordinated operation of the hydro system. These operating requirements include but are not limited to storage content limits determined by rule curves, maximum project draft rates determined by each project owner, and flow and spill objectives described in the NOAA Fisheries and USFWS BiOps listed above and as provided by the 2012 PNCA data submittals. Some deviations from the 2012 PNCA data submittals are necessary to more accurately model anticipated operations for the rate period, such as fine-tuning the study to reflect typical in-season management decisions that are not reflected in the 2012 PNCA data submittals.

1
2 The hydro regulation studies include sets of power and non-power requirements for each year of
3 the rate period. Specific assumptions for the HYDSIM hydro regulation study are detailed in the
4 Documentation, BP-14-E-BPA-03A, section 3.

5
6 Several changes have been made to the hydro modeling since the BP-12 Loads and Resources
7 Study. These changes have been made as part of BPA's continuous efforts to incorporate the
8 most recent available data in the model and to improve hydro regulation modeling to more
9 accurately reflect operations. The following are the updates to the HYDSIM hydro regulation
10 studies included in this Study:

- 11 • The study has been expanded to an 80-year study based on the 2010 Level Modified
12 Streamflow data published in August 2011. These data reflect historical estimates of
13 October 1928 through September 2008 unregulated streamflow assuming estimated
14 irrigation depletion from 2010. This is not just ten years of new streamflow data
15 added to the previous 70-year data set; rather, it is an entirely new data set that revises
16 the previous 70 years of streamflow and adds 10 more years of streamflow data.
- 17 • All projects have been updated according to 2012 PNCA data. These updates are too
18 numerous to list in their entirety and tend to be minor. The following are some of the
19 more noteworthy PNCA data updates:
 - 20 – Federal project plant data, which the HYDSIM model uses to estimate generation
21 at each project, were updated to better reflect actual generation estimates at most
22 of the Federal projects.
 - 23 – Flow requirements were updated, such as changing Dworshak's minimum
24 required flow from 1.3 kcfs to 1.6 kcfs.
- 25 • Brownlee operations have been updated based on the most recent data provided by
26 the USACE reflecting expected operations for the new 80-year streamflow data.

- Flood Control rule curves have been updated to the most recent data provided by the USACE. These new flood control rule curves include an additional ten years of flood control rules needed for the 80-year study. The USACE was unable to provide a fully revised 80-year flood control data set but may be able to provide this data in time for the Final Proposal.
- Canadian project operations have been updated based on the surrogate 2014 DOP and 2015 DOP described earlier.
- Non-Treaty Storage Agreement (NTSA) operations have been included in this study based on the long-term agreement signed with B.C. Hydro in April 2012. The NTSA allows additional shaping of Columbia River flows for power and fish operations by utilizing non-Treaty storage in Canadian storage reservoirs. The NTSA allows water to be released from Canadian non-Treaty storage during the spring of dry years. The NTSA also allows water to be released in the summer instead of the spring during years when the spring flow targets from the 2008 NOAA BiOp are being met.
- Loads and independent hydro projects have been updated based on the numbers presented in this study. HYDSIM uses the residual hydro load for the region, which is calculated by subtracting the regional firm non-hydro resources from the total regional firm load. The residual hydro load in the HYDSIM BP-14 study is several hundred megawatts higher than in the BP-12 HYDSIM study.
- Miscellaneous updates have been made to better reflect expected actual operations:
 - Grand Coulee’s January through March operation has been reshaped to prevent the project from drafting too deeply for winter fish flow requirements based on input from USBR and NOAA. Grand Coulee will draft no lower than elevation 1270 feet in December, 1260 feet in January, 1250 feet in February, and 1240 feet in March and April. These are not new operating restrictions but estimates for simulating likely in-season management decisions.

- Updated modeling has been incorporated to remove forced drafts for drum gate maintenance at Grand Coulee during FY 2014. This is because enough maintenance has been performed during the past few years to ensure the maintenance requirement can be met without forcing the draft specifically for maintenance purposes in FY 2014.
- Kerr’s operation has been updated to reflect more recent typical operations.
- There are no updates to spill assumptions for fish passage since the BP-12 Loads and Resources Study.
- Federal powerhouse availability factors have been updated based on the average actual 2007–2011 powerhouse outages at most projects, additional large planned outages, and more recent wind and operating reserve requirement assumptions. See Generation Inputs Study, BP-14-FS-BPA-05, sections 2 and 4.5, for details on reserve requirements. These wind and operating reserve requirement updates are incorporated into the availability factors in HYDSIM and reduce the powerhouse generating capability. The additional large planned outages at Chief Joseph are reflected by basing Chief Joseph powerhouse availability factors on the average actual 2010 and 2011 outages. The additional large planned outages at Grand Coulee are reflected by basing Grand Coulee availability factors on 2011 average actual outages reflecting two large 805 MW units out of service at all times.
- The lack of market spill has been updated based on estimates from the AURORAxmp model.

These HYDSIM study changes generally decrease firm generation (annual average during 1937 critical water conditions) and increase average generation (80-year annual average). The study decreases the BP-14 rate period annual average Federal generation about 60 aMW in 1937 critical water conditions compared to the BP-12 rate period annual average. The study

1 increases the BP-14 rate period 80-year average Federal generation about 60 aMW compared to
2 the BP-12 rate period 70-year average. The separate effects of each modeling change have not
3 been analyzed. However, the changes are largely attributable to a few of the more significant
4 changes, which include the updates to Grand Coulee operations, the Canadian Treaty and
5 non-Treaty operations, the new streamflow data, and the AURORA estimates of lack-of-market
6 spill.

7
8 The assumptions in the hydro regulation studies for FY 2014 and FY 2015 are all the same for
9 the two years except for the following:

- 10 (1) The hydro availability factors used to model anticipated unit outages and the standard
11 reserve requirements are estimated for each study year. The outages associated with
12 anticipated maintenance are the same in the FY 2014 and FY 2015 studies. The
13 availability factors are adjusted to reflect the different amount of reserve requirements
14 estimated for each year, including the forecast wind reserve requirements (operating
15 reserves and increases and decreases in balancing reserve capacity (*incs* and *decs*)).
16 See Generation Inputs Study, BP-14-E-BPA-05, sections 2 and 4.5, for details on
17 wind reserve assumptions.
- 18 (2) The residual hydro loads assumed in HYDSIM are different in the two hydro
19 regulation studies. The loads incorporated in the FY 2015 hydro regulation study are
20 slightly higher than the loads projected for the FY 2014 hydro regulation study,
21 mainly due to load growth, but also due to changes in regional thermal resources.
- 22 (3) The amounts of spill due to lack of market are different in the two hydro regulation
23 studies. These differences come from the AURORAxmp model, which simulated the
24 different anticipated market conditions in each of the two years.
- 25 (4) The Grand Coulee drum gate maintenance operation is not included in FY 2014 but is
26 included in FY 2015, as described previously.

(5) The Canadian operations for FY14 are based on the surrogate 2014 DOP, and the Canadian operations for FY 2015 are based on the surrogate 2015 DOP, as described previously.

3.1.2.1.2 80-Year Modified Streamflows

The HYDSIM model uses streamflows from historical years as the basis for estimating power production of the hydroelectric system. The HYDSIM studies are developed using the year-2010 level of modified historical streamflows. Historical streamflows are modified to reflect the changes over time due to the effects of irrigation and consumptive diversion demand, return flow, and changes in contents of upstream reservoirs and lakes. These modified streamflows were developed under a BPA contract funded by the PNCA parties. The modified streamflows are also adjusted in this study to include updated estimates of Grand Coulee irrigation pumping and resulting downstream return flows, using data provided by USBR in its 2012 PNCA data submittal.

Eighty years of streamflow data are used because hydro is a resource with a high degree of variability in generation from year to year. The Study uses an 80-year hydro regulation study to forecast the expected operations of the regulated hydro projects for varying hydro conditions. Approximately 80 percent of BPA's Federal system resource stack is comprised of hydro generation, which can vary annually by about 5,000 aMW depending on water conditions. HYDSIM estimates regulated hydro project generation for varying water conditions and takes into account specific flows, volumes of water, elevations at dams, biological opinions, and many other aspects of the hydro system. Given the variability of hydro generation, as many years as possible are modeled; 80 years is the largest number of years for which all the historical data are available as needed by HYDSIM.

1 Additionally, BPA has generation estimates for other hydro projects that are based on
2 80 historical water conditions, October 1928 through September 2008. These projects are called
3 “independent hydro” projects because their operations are not regulated in this HYDSIM study,
4 primarily because they have much less storage capability than the hydro projects in the Columbia
5 River Basin regulated in the HYDSIM study. The independent hydro projects usually have
6 generation estimates for each of the 80 water years of record. Most of these hydro projects are
7 not federally owned, and their generation estimates are updated with the cooperation of each
8 project owner. For those independent hydro projects that did not have data for all 80 water
9 years, generation estimates were expanded using the project’s median generation to estimate
10 generation for the additional water years.

12 **3.1.2.1.3 1937 Critical Water for Firm Planning**

13 To ensure that it has sufficient generation to meet load, BPA bases its resource planning on
14 critical water conditions. Critical water conditions are when the PNW hydro system would
15 produce the least amount of power while taking into account the historical streamflow record,
16 power and non-power operating constraints, the planned operation of non-hydro resources, and
17 system load requirements. For operational purposes, BPA considers critical water conditions to
18 be the eight-month critical period of September 1936 through April 1937. For planning purposes
19 and to align with the fiscal years used in this Study, however, the Study uses the historical
20 streamflows from October 1936 through September 1937 water conditions as the critical period.
21 This is designated “1937 critical water conditions.” The hydro generation estimates under 1937
22 critical water conditions determine the critical period firm energy for the regulated and
23 independent hydro projects. This is called the FELCC, or firm energy load carrying capability.

3.1.2.1.4 Generation Performance Curves

The HYDSIM generation forecast for this analysis incorporates updated generation performance curves for the regulated hydro Federal hydro projects, and therefore no generation additions for additional efficiency improvements are needed.

3.1.2.2 Independent Hydro Generation Forecast

Federal system independent hydro includes hydro projects whose generation output typically varies by water conditions; however, the generation forecasts for these projects are not modeled or regulated in the HYDSIM model. BPA markets the power from independent hydro projects that are owned and operated by USBR, USACE, or other project owners. Federal system independent hydro generation estimates are provided by individual project owners for 80 water years (October 1928 through September 2008). These include power purchased from hydro projects owned by Lewis County Public Utility District (Cowlitz Falls), Mission Valley (Big Creek), and Idaho Falls Power (Bulb Turbine projects). Documentation Tables 2.2.1, 2.2.2, and 2.2.3, lines 1-22, list the hydro projects included in BPA's Independent Hydro Generation forecast.

The energy estimates for Federal system independent hydro generation used in this Study are summarized in Documentation section 2.2, Table 2.2.1 for energy, Table 2.2.2 for HLH, and Table 2.2.3 for LLH. This forecast is also included in the calculation of the load-resource balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on line 15 (Independent Hydro - Net).

The HLH-LLH split for the independent hydro generation estimates is developed based on actual historical data. This Study provides the HLH and LLH Federal system independent hydro generation to the Power Risk and Market Price Study, BP-14-E-BPA-04.

3.1.3 Other Federal System Generation

Other Federal system generation includes the purchased output from non-federally owned projects and project generation that is directly assigned to BPA. Other Federal system generation estimates are detailed for monthly energy in aMW and HLH and LLH megawatthours as follows.

- (1) Cogeneration resources include the Georgia-Pacific (Wauna) project. This project is detailed in Documentation Table 2.3.1 for energy, Table 2.3.2 for HLH, and Table 2.3.3 for LLH. This forecast is also included in the calculation of the load-resource balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on line 17 (Cogeneration Resources).
- (2) Columbia Generating Station (CGS), which incorporates facility improvements and a two-year refueling cycle. CGS details are shown in Documentation Table 2.4.1 for energy, Table 2.4.2 for HLH, and Table 2.4.3 for LLH. This forecast is also included in the calculation of the load-resource balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on line 19 (Large Thermal Resources).
- (3) Renewable resources, which include wind resources (Federal purchases of shares of the Condon Wind Project; Foote Creek 1, 2, and 4 Wind Projects; Klondike I Wind Project; Klondike III Wind Project; Stateline Wind project; Ashland Solar; and White Bluffs Solar). These projects are detailed in Documentation section 2.5, Table 2.5.1 for energy, Table 2.5.2 for HLH, and Table 2.5.3 for LLH. This forecast is also included in the calculation of the load-resource balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on line 20 (Renewable Resources).
- (4) Small Hydro Resources include the Dworshak/Clearwater Small Hydro project and Rocky Brook hydro project. Small Hydro Resources are detailed in Documentation Table 2.6.1 for energy, Table 2.6.2 for HLH, and Table 2.6.3 for LLH. This forecast is also included in the calculation of the load-resource balance, Table 4.1.1 for

energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on line 21 (Small Hydro Resources).

3.1.4 Federal System Contract Purchases

BPA purchases or receives power under a variety of contractual arrangements to help meet Federal load obligations. The contracts are categorized as (1) power purchases; (2) power or energy exchange purchases; (3) capacity sales or capacity-for-energy exchange contracts; (4) power purchased or assigned to BPA under the Columbia River Treaty; and (5) transmission loss returns under Slice/Block contracts. These arrangements are collectively called “Contract Purchases.” BPA’s Contract Purchases are considered firm resources that are delivered to the Federal system regardless of weather, water, or economic conditions. The transmission loss returns category captures the return of Slice transmission losses to the Federal system as part of the Slice/Block contracts, which acts as a Federal system resource.

BPA’s expected Contract Purchases are detailed in the Documentation as follows. Imports are found in Table 2.7.1 for energy, Table 2.7.2 for HLH, and Table 2.7.3 for LLH. Non-Federal Canadian Entitlement Return deliveries are found in Table 2.8.1 for energy, Table 2.8.2 for HLH, and Table 2.8.3 for LLH. Intra-Regional Transfers are found in Table 2.9.1 for energy, Table 2.9.2 for HLH, and Table 2.9.3 for LLH. (Federal Transmission Loss Returns does not have its own table but is included in the load-resource balance calculation described below.)

The forecast for Contract Purchases is also included in the calculation of the load-resource balance, Table 4.1.1 for energy, Table 4.1.2 for HLH, and Table 4.1.3 for LLH, on lines 24 (Imports), 25 (Regional Transfers (In)), 26 (Non-Fed CER), and 27 (Slice Transmission Loss Returns).

1 Contract Purchases do not include purchases under BPA power contracts made to meet monthly
2 within-year energy deficits or trading floor purchases (including purchases to meet Tier 2 load
3 obligations served by BPA). BPA has made several within-year balancing purchases to cover
4 increasing amounts of forecast winter HLH energy deficits for FY 2014. These purchases are
5 called “winter hedging purchases.” In addition, BPA has made other trading floor purchases that
6 continue into FY 2015, such as to meet anticipated Tier 2 obligations. Month-to-month trading
7 floor activity to meet monthly deficits such as winter hedging purchases and trading floor
8 transactions made to meet anticipated Tier 2 loads are not included in the calculation of BPA’s
9 firm annual load and resource balance in the Loads and Resources Study. These contracts are
10 are reflected in the Power Risk and Market Price Study, BP-14-E-BPA-04.

11
12 Contract purchases do include system augmentation purchase estimates that are forecast to meet
13 any annual deficits of the Federal system loads and resources balance. Calculation of system
14 augmentation purchases is discussed in section 4.2.

16 **3.1.5 Federal System Transmission Losses**

17 Federal system transmission loss estimates are treated as generation reductions in the Study.
18 These losses are calculated monthly and vary by water conditions. Transmission Services
19 provided the analysis of expected Federal system transmission loss factors for energy and peak
20 load conditions. The Federal system transmission loss factors used in this Study were developed
21 in 1992 and reaffirmed by BPA’s Transmission business unit in 1994 and 2000. These studies
22 concluded that the Federal system loss factors for BPA’s transmission system are 2.82 percent
23 for energy, HLH and LLH; and 3.35 percent for peak deliveries when averaged over the year,
24 when applied to generation.

The loss factors have several components that combine to give the estimate of losses typically associated with Federal system generation: (1) step-up transformers from generation to the high-voltage transmission network; (2) high-voltage network transmission; (3) transfers to Federal loads over non-Federal transmission systems; and (4) step-down transformers from high-voltage transmission to low-voltage delivery. The estimated magnitude of those loss factor components for energy is as follows:

- (1) Step-up transformers between the Federal generation and the transmission network average 0.31 percent.
- (2) Network loss factor averages 1.90 percent.
- (3) Some loads are general transfer customers, which have additional losses crossing non-Federal transmission averaging 0.34 percent.
- (4) Some loads have step-down transformer losses averaging 0.27 percent.

The Power Risk and Market Price Study, BP-14-E-BPA-04, uses the same transmission loss factors that are used in this Study. The Power Rate Study, BP-14-E-BPA-01, uses the same transmission loss factors, but they are mathematically converted to be applied to loads.

3.2 Regional Hydro Resources

3.2.1 Overview

This Study produces total PNW regional hydro resource estimates for FY 2014–2015 to provide input into the AURORAxmp model for the Power Risk and Market Price Study, BP-14-E-BPA-04.

3.2.2 PNW Regional 80 Water Year Hydro Generation

PNW regional hydro resource estimates are one of the inputs into the AURORAxmp model and are comprised of regulated and independent hydro, plus small hydro for FY 2014–2015 for all PNW hydro resources, Federal and non-Federal. Regulated hydro project generation estimates

for this Study are developed, by month, for each of the 80 water years (October 1928 through September 2008) using the same HYDSIM study described in section 3.1.2.1. Independent hydro generation estimates are provided by the project owners for the same 80 water years. Generation estimates for the small hydro projects are provided by the individual project owners and are assumed not to vary by water year.

The regional regulated, independent, and small hydro totals are summarized for energy over 80 water years for FY 2014–2015 and are shown in Documentation section 2.10, Tables 2.9.1 and 2.9.2.

3.3 4(h)(10)(C) Credits

3.3.1 Overview

The Pacific Northwest Electric Power Planning and Conservation Act (Northwest Power Act) directs BPA to make expenditures to protect, mitigate, and enhance fish and wildlife affected by the development and operation of Federal hydroelectric projects in the Columbia River Basin and its tributaries. These expenditures are to be made in a manner consistent with the Power Plan and Fish and Wildlife Program developed by the NPCC and consistent with other purposes of the Northwest Power Act. 16 U.S.C. §§ 839–839h. Section 4(h)(10)(C) of the Northwest Power Act requires that the costs of mitigating these impacts are properly accounted for among the various purposes of the hydroelectric projects by making sure that when Bonneville funds mitigation on behalf of both power and non-power project purposes, ratepayers can recoup the non-power share. The non-power purposes include flood control, irrigation, recreation, and navigation, and the percentage of costs attributable to non-power purposes is 22.3 percent. This percentage is the systemwide average of cost allocations for non-power purposes of the FCRPS provided by the USBR and USACE for their hydropower projects.

1 Following the Northwest Power Act’s requirement for appropriate cost allocation, BPA annually
2 recoups the non-power portion of costs associated with fish measures through “4(h)(10)(C)
3 credits” against BPA’s payments to the U.S. Treasury. This Study estimates the replacement
4 power purchases resulting from changes in hydro system operations to benefit fish and wildlife.
5 These power purchases are part of the calculation of 4(h)(10)(C) credits in Power Risk and
6 Market Price Study section 2.6.1. The operations to benefit fish and wildlife are described in
7 section 3.1.2.1.1.
8

9 **3.3.2 Forecast of Power Purchases Eligible for 4(h)(10)(C) Credits**

10 The power purchases eligible for 4(h)(10)(C) credits are estimated by comparing power purchase
11 estimates between two HYDSIM hydro regulation studies. The first hydro regulation study,
12 termed the “with-fish” study, models hydro system operations using current requirements for fish
13 mitigation and wildlife enhancement under 80 historical water year conditions (October 1928
14 through September 2008). The BP-14 Initial Proposal HYDSIM study is used as the “with-fish”
15 study. The second hydro regulation study, called the “no-fish” study, models the hydro system
16 operation assuming no operational changes were made to benefit fish and wildlife, using the
17 same 80 historical water-year conditions.
18

19 BPA estimates the power purchases that would be required to meet a specific firm load
20 (described later) under the with-fish study and the power purchases that would be required to
21 meet the same specific firm load under the no-fish study. The 4(h)(10)(C) credits do not pertain
22 to the entire generation difference between the with-fish study and the no-fish study; instead, the
23 credits pertain to only a portion of the additional power purchases in the with-fish study
24 compared to the power purchases in the no-fish study. BPA receives section 4(h)(10)(C) credits
25 for the non-power portion (22.3 percent) of the additional power purchases it must make in the
26 with-fish study relative to the no-fish study.

1
2 The specific firm load used in the calculation of 4(h)(10)(C) credits was a part of the original
3 negotiated arrangement between the U.S. Department of Energy and U.S. Department of
4 Treasury allowing BPA to claim the credits. A fundamental principle of this arrangement for
5 claiming section 4(h)(10)(C) credits is that the calculation is not to be affected by BPA's
6 marketing decisions. In order to separate the credit calculation from BPA marketing decisions,
7 4(h)(10)(C) credits are calculated using the load that could have been served with certainty while
8 drafting the system from full to empty without fish operations and under the worst
9 energy-producing water conditions in the 80-year record (referred to as the critical period, which
10 is 1929–1932 in the no-fish study). This FELCC is the amount of firm load that BPA would
11 have been entitled to sell without fish operations and is used as the firm load in the
12 section 4(h)(10)(C) power purchases analysis. The differences between the Federal FELCC and
13 the Federal generation in the with-fish study determine the power purchases under the with-fish
14 study. The differences between the Federal FELCC and the Federal generation in the no-fish
15 study determine the power purchases under the no-fish study. The instances where power
16 purchases are greater in the with-fish study compared to the no-fish study result in power
17 purchases eligible for section 4(h)(10)(C) credits. Alternatively, when power purchases are less
18 in the with-fish study than in the no-fish study, the difference constitutes a negative
19 section 4(h)(10)(C) credit.

20
21 The differences in energy purchase amounts between the with-fish and no-fish hydro studies are
22 calculated for each period and water condition of the 80 water year studies. The differences are
23 shown in Documentation Table 2.11. These power purchases are used as inputs to the Power
24 Risk and Market Price Study, BP-14-FS-BPA-04, where, combined with AURORAxmp market
25 price estimates, they are used to calculate the 4(h)(10)(C) credits for power purchases. The

1 non-power portion (22.3 percent) of the average expense for these purchases is used as the
2 forecast of section 4(h)(10)(C) credits for Federal hydro system fish operations.

3 4 **3.4 Use of Tier 1 System Firm Critical Output Calculation**

5 A forecast of Tier 1 System Firm Critical Output (T1SFCO) for use in the rate case is calculated
6 in the same manner as in the 2012 RHW process. This T1SFCO is part of the calculation of
7 the Tier 1 System output used for this study. The Tier 1 System output is the sum of the
8 T1SFCO plus RHW Augmentation. See TRM, Definitions. For the rate period, FY 2014–
9 2015, the RHW Tier 1 System Capability was determined in the RHW process, which ended
10 September 30, 2012. The RHW process rescaled the CHWMs to an augmented Tier 1 System
11 (RHW Tier 1 System Capability). These rescaled CHWM are the RHWs for the rate period.

12
13 Resource forecasts for this Study have been updated since the RHW process as allowed in the
14 TRM. TRM section 3.1.1. These updates changed the Tier 1 System output. Since the Slice
15 obligation has two parts, the Slice Right to Power and Slice Block, changes to the Tier 1 System
16 output will revise the proportion of a customer's Slice Right to Power and Slice Block. In order
17 to maintain the same contractual obligations to Slice customers established in the RHW
18 process, any increase or decrease in the Slice Right to Power will result in a equal decrease or
19 increase in the Slice Block. The rate case Tier 1 System output is estimated to be about
20 7,058 aMW when averaged over the two-year period. The Slice right to power is calculated by
21 multiplying the Slice Percent Adjusted Ratio of 26.8126 percent by the Tier 1 System output.
22 Supporting tables for the T1SFCO used in this Study for the calculation of the updated Tier 1
23 System output are provided in Documentation section 2.12. Table 2.12.1 contains the summary
24 of the T1SFCO for FY 2014–2015. Table 2.12.2 contains the Federal System Hydro Generation.
25 Table 2.12.3 contains the Designated Non-Federally Owned Resources. Table 2.12.4 contains

the Designated BPA Contract Purchases. Documentation Table 2.12.5 contains the Designated
BPA System Obligations.

This page intentionally left blank.

4. FEDERAL SYSTEM LOAD-RESOURCE BALANCE

4.1 Overview

For BPA to do operational planning and set power rates, the Federal system must be in load and resource balance; that is, BPA must forecast that it has enough resources available to serve its forecast loads during critical water conditions. The load-resource balance is composed of the monthly energy amounts of BPA's resources, which include hydro, non-hydro, and contract purchases; less BPA's load obligations, which are comprised of BPA's PSC obligations and Other Contract Obligations.

To determine whether the Federal system is in load-resource balance, the amount of BPA's annual forecast firm energy resources under 1937 critical water conditions is estimated. If BPA's expected firm energy resources under critical water conditions are sufficient to serve BPA's expected load obligations, then BPA is considered to be in load-resource balance. If BPA's resources under critical water conditions are less than its load obligations, BPA is assumed to purchase power or otherwise secure resources to avoid Federal system annual energy deficits. Purchases to meet these annual firm energy deficits are called system augmentation purchases. Annual system augmentation purchases may not fully meet monthly Federal system HLH or LLH energy deficits. Additional purchases made to meet these monthly HLH or LLH energy deficits are called balancing purchases.

4.2 Federal System Energy Load-Resource Balance

Table 2 shows a summary of the Federal system annual energy load-resource balance. Under 1937 critical water conditions, the Federal system is expected to be in firm annual energy load-resource balance for FY 2014–2015. This result assumes 118 aMW of system augmentation purchases for FY 2014 and 466 aMW of augmentation purchases for FY 2015.

The components of the Federal system load-resource balance are shown in Table 3, for energy; and in Documentation section 4, Table 4.1.1 for energy, Table 4.2.1 for HLH, and Table 4.3.1 for LLH.

Table 1
Regional Dialogue Preference Load Obligations
Forecast By Product
Annual Energy in aMW

A	B	C
Fiscal Year	2014	2015
Preference Customer Load Obligations		
1. Load-Following Customers (Including Federal Agencies and reduced for BPA-funded conservation) ^{1/}	3,140	3,197
2. Slice Block	1,809	1,899
3. Slice Right to Power	1,943	1,867
4. Total Preference Load Obligations (sum of lines 1 through 4)	6,892	6,963

^{1/} BPA-Funded conservation is estimated at 29.7 aMW for FY 2014 and FY 2015.

Table 2
Loads and Resources – Federal System Summary
Annual Energy in aMW

A	B	C
Fiscal Year	2014	2015
Firm Obligations		
1. Non-Utility Obligations	611	612
2. Transfers Out	8,184	8,379
3. Total Net Obligations	8,184	8,235
Net Resources		
4. Net Hydro Resources	8,066	8,446
5. Other Resources	1,112	960
6. Contract Purchases (Not including System Augmentation)	267	248
7. System Augmentation Purchases	118	466
8. Federal System Transmission Losses	-237	-239
9. Net Total Resources (Sum lines 4 through 8)	8,184	8,235
Surplus/Deficit		
10. Firm Surplus/Deficit (line 9 - line 3)	0	0

Table 3
Loads and Resources – Federal System Components
Annual Energy in aMW

A	B	C
Energy (aMW)	2014	2015
Firm Obligations		
1. Non-Utility Obligations Total	611	612
2. Fed. Agencies 2012 PSC	123	124
3. USBR Obligation	176	176
4. DSI Obligation	312	312
5. Transfers Out Total	7,573	7,623
6. Load-Following 2012 PSC	3,140	3,197
7. Slice Block 2012 PSC	1,809	1,899
8. Slice Right to Power 2012 PSC	1,943	1,857
9. Exports	586	566
10. Intra-Regional Transfers (Out)	94	93.6
11. Federal Diversity	0	0
12. Total Firm Obligations (line 1+5)	8,184	8,235
Net Resources		
13. Net Hydro Resources Total	6,924	6,800
14. Regulated Hydro – Net	6,571	6,446
15. Independent Hydro – Net	354	354
16. Other Resources Total	1,112	960
17. Cogeneration Resources	19.2	19.2
18. Combustion Turbines	0	0
19. Large Thermal Resources	1,030	878
20. Renewable Resources	60.3	60.3
21. Small Hydro Resources	2.9	2.9
22. Small Thermal & Misc. Resources	0	
23. Contract Purchases Total	385	714
24. Imports	52.7	50.9
25. Intra-Regional Transfers (In)	41.1	25.8
26. Non-Federal CER	136	136
27. Slice Transmission Loss Return	36.6	35.2
28. Augmentation Purchases	118	466
29. Reserves & Losses	-237	-239
30. Contingency Reserves (Non-Spinning)	0	0
31. Contingency Reserves (Spinning)	0	0
32. Generation Imbalance Reserves	0	0
33. Load-Following Reserves	0	0
34. Federal Transmission Losses	-237	-239
35. Total Net Resources (line 13+16+23+29)	8,184	8,235
36. Total Firm Surplus/Deficit (line 35 – line 12)	0	0

This page intentionally left blank.

